



DoP Number: J-Y(St)Y-0101

1. Unique identification code of the product type: J-Y(St)Y...Lg
2. Description of the product type: J-Y(St)Y Fire Alarm Cable VDE 0815
3. Intended use: Supply of communications in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke
4. Contact address: Emek Kablo San. ve Tic. Ltd. Şti.
Halil Rifat Paşa Mahallesi,
Perpa Ticaret Merkezi, A Blok
Kat: 4- 5 No: 135/137 34384
Okmeydanı-Şişli/İSTANBUL
Turkey
Tel. +90 212 210 3955
Email: info@emekkablo.com

5. System or systems of assessment and verification of constancy of performance of the construction product:

System 3

6. Notified body code:

1783

7. Declared performance:

Essential characteristics	Performance	Harmonized technical specification
Reaction to fire	Eca	EN 50575:2014 + A1:2016
Dangerous substances	None	

8. The performance of the product as identified is in conformity with the declared performance in point 7.

9. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Name and function signer

Quality Manager

Gürol UÇAR

Place

İstanbul

Date

20/07/2017

Signature